

VOC Content Test Certificate

Wednesday March 16th, 2010

Manufacturer: RLA Polymers Pty Ltd. (Po Box 147 Kilsyth Vic 3137)

Sample Description: Rlaflex 1 part

Date Tested: March 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC)
in Various Materials as referenced by South Coast Air Quality Management
Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>Rlaflex 1 Part</p>
Ceramic Tile Adhesive 65 grams per Litre	2 grams per Litre as VOC content per coating
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>Rlaflex 1 Part</p>
Ceramic Tile Adhesive 65 grams per Litre	2 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1003-06