

# VOC Content Test Certificate

Wednesday March 16<sup>th</sup>, 2010

Manufacturer: RLA Polymers Pty Ltd. (Po Box 147 Kilsyth Vic 3137)

Sample Description: Techbond 14

Date Tested: March 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC)  
in Various Materials as referenced by South Coast Air Quality Management  
Division (SCAQMD) Rule 1168.

Test Data:

<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b></p>	<p><b>TECHBOND 14</b></p>
Ceramic Tile Adhesive 65 grams per Litre	<1 grams per Litre as VOC content per coating
<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b></p>	<p><b>TECHBOND 14 14</b></p>
Ceramic Tile Adhesive 65 grams per Litre	<1 grams per Litre as VOC content per coating



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F1003-06